



- EDGE CONDITIONS LEGEND:**
- ① - REMOVE EXIST. DRIP EDGE METAL AND GUTTER. INSTALL NEW WOOD BLOCKING AND TAPERED EDGE STRIP TO MATCH HEIGHT OF NEW ROOF SYSTEM, TO PROMOTE DRAINAGE INTO GUTTER AND PREVENT PONDING ALONG ROOF EDGE. INSTALL NEW 12" X 12" BOX GUTTER W/ DOWNSPOUTS TO MATCH EXISTING LOCATIONS TO MATCH EXISTING CONFIGURATION (SEE DET 0001).
 - ② - 1'-3" (H) TO 5'-0" (HXVARIES) X 1'-1" TO 1'-2" (WXVARIES) PARAPET WALL. REMOVE EXISTING METAL COPING, WALL FLASHINGS AND ANY LOW METAL COUNTER FLASHING. INSTALL FULLY ADHERED NEW WALL FLASHING UP OVER EXIST. TOP PLATE AND DOWN FRONT FACE. INSTALL NEW TWO PIECE METAL FASCIA (SEE DET. 0002).
 - ③ - 1'-0" (H) WALL FLASHING. REMOVE FLASHINGS. INSTALL FULLY ADHERED NEW WALL FLASHING. INSTALL TERM BAR, SEALANT AND SLIP FLASHING TO BACKSIDE OF EXISTING METAL COUNTER FLASHING TO REMAIN (SEE DET 0003).
 - ④ - 1'-0" TO 12'-0" (HXVARIES) WALL FLASHING. REMOVE FLASHINGS INCLUDING LOW METAL COUNTER FLASHING. INSTALL FULLY ADHERED NEW WALL FLASHING. INSTALL TERM BAR, SEALANT AND SLIP FLASHING TO BACKSIDE OF EXISTING METAL COUNTER FLASHING TO REMAIN (SEE DET 0003).
NOTE: INSTALL INTERMEDIATE HORIZONTAL TERM BARS IF REQUIRED BY MANUFACTURER DUE TO FLASHING HEIGHTS.
 - ⑤ - 1'-0" (H) WALL FLASHING. REMOVE FLASHINGS. INSTALL FULLY ADHERED NEW WALL FLASHING. INSTALL TERM BAR, SEALANT AND LOOSEN BOTTOM EDGE OF METAL ROOF PANELS TO INSTALL SLIP FLASHING TO BACKSIDE OF EXISTING METAL ROOF PANELS TO REMAIN. RE-SECURE BOTTOM EDGE OF METAL ROOF PANELS AND APPLY SEALANT TO ANY EXPOSED FASTENER HEADS AS MAY BE REQUIRED (SEE DET 0003).
 - ⑥ - 2'-0" (H) WALL FLASHING. REMOVE ALL FLASHINGS. FULLY ADHERE NEW WALL FLASHING. INSTALL TERM BAR, SEALANT AND NEW SURFACE MOUNTED COUNTER FLASHING W/ SEALANT JOINT (SEE DET 0004).

NOTE: INSTALL 1/2" MECH ATTACHED DENS DECK OVER ALL FLASHING SUBSTRATES WHERE BUR FLASHINGS ARE REMOVED

- PENETRATIONS LIST:**
- CURBS**
- A - 10'6"X45' PENTHOUSE (ACCESS TO ROOF)
 - B - 9'X61' 8-BEAMS ON (4) 7" WIDE ROUND SUPPORTS (CHILLER UNITS)
 - C - 8'X44' LARGE RTU
 - D - 4'X65' RTU
 - E - 3'X4' RTU
 - F - CONDENSER ON 4'X7'6" I-BEAMS ON (4) 5" ROUND SUPPORTS IN 8'X8" PITCH BOXES
- PIPES**
- 1" - 7
 - 2" - 13
 - 3" - 6
 - 4" - 10
- VENT STACKS**
- 6" - 3
 - 8" - 4
 - 10" - 5
- SATELLITE DISH PADS (SET ON WALK PADS)**
- 3'X3' - 1
 - 6'6"X6" - 1
 - 1'9"X1'9" RTV - 6
 - 1'9"X1'9" KITCHEN EXHAUST FAN - 3
 - 2'X2' KITCHEN EXHAUST FAN - 1
 - 2'X6"X2'6" KITCHEN EXHAUST FAN - 1
 - 1'6"X1'6" RTV - 2
- SATELLITE DISH ON 8" ROUND SUPPORT - 1**

General Notes

DISCLAIMER

ALL DEAD, DESIGNED ARRANGEMENTS, AND PLANS INDICATED OR REPRESENTED BY THIS DRAWING ARE OWNED BY AND ARE THE PROPERTY OF ROOFINGPROJECTS.COM AND WERE CREATED, EVOLVED AND DEVELOPED FOR USE ON AND IN CONNECTION WITH THE SPECIFIC PROJECT. NONE OF SUCH LOGOS, DESIGNS, ARRANGEMENTS OR MARKINGS SHALL BE USED BY OR DISCLOSED TO ANY THIRD PARTY WHATSOEVER WITHOUT THE WRITTEN PERMISSION OF ROOFINGPROJECTS.COM.

WRITTEN DIMENSIONS ON THIS DRAWING SHALL TAKE PRECEDENCE OVER SCALED DIMENSIONS. CONTRACTORS SHALL VERIFY AND BE RESPONSIBLE FOR ALL DIMENSIONS AND CONDITIONS ON THE JOB AND THIS OFFICE MUST BE NOTIFIED OF ANY VARIATIONS FROM THE DIMENSIONS AND CONDITIONS SHOWN BY THESE DRAWINGS.



No.	Revision/Issue	Date

Firm Name and Address

RoofingProjects-com
17 High Street
Suite 301
Norwalk, CT
06851

Project Name and Address

2026
Safeway #1815
337 E Ridgeville Blvd
Mt Airy, MD 21771

Project	Sheet
Date April 20, 2026	1
Scale 1/16" = 1'-0"	